

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE-Fire Line Construction Inspection	Steve Robbins	Partial	Wednesday, September 27, 2017

Informational

1 The concrete is late, they will pour the thrust blocks later and not backfill so i can look at it in the morning.Steve Robbins 09/27/2017 3:32 PM

DE-Fire Line Construction Inspection	Steve Robbins	Partial	Wednesday, September 27, 2017
--------------------------------------	---------------	---------	-------------------------------

Informational

1 This morning I asked the contractors to make sure we have epoxy coated fitting for the fire line. This afternoon they will pour the thrust block on the 8" main from the fireline.Steve Robbins 09/27/2017 8:24 AM

**Comments:**