

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE-Fire Line Construction Inspection	Steve Robbins	Partial	Thursday, September 28, 2017

Informational

- 1 The thrust block for the fireline where the tap was done has been poured and , the valve has been wrapped and rock has been installed. The contractor is going to backfill and get things set up for the water tap for the 2" meter.Steve Robbins 09/28/2017 8:32 AM

Comments: