

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161750, Building Permit - Commercial

Address: 783 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Thursday, September 28, 2017

Partial Correction

1 Misc

OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT STAIRWELLS:

NORTH STAIRWELL:

BASEMENT LEVEL 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER;

THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; 2ND LAYER AT WELL FACE;

4TH FLOOR: 1ST LAYER @ WELL FACE; 2ND LAYER AT WELL FACE;

SOUTH STAIRWELL:

BASEMENT 1ST LAYER, 2ND LAYER

FIRST FLOOR: 1ST & 2ND LAYERS @ WELL FACE + PRE-ROCK AT JOIST BAYS;

SECOND FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST

		BAYS; 2ND LAYER;
		THIRD FLOOR: 1ST LAYER @ WELL FACE + PRE-ROCK AT JOIST BAYS; 2ND LAYER PRE-ROCK AT JOIST BAYS; 2ND LAYER AT WELL FACE;
		4TH FLOOR: 1ST LAYER @ WELL FACE; 2ND LAYER @ WELL FACE;
Partial Correction		
2	Misc	OK TO COVER WHEN READY COMPONENTS OF 5/8" TYPE X MOLD-TOUGH GWB RATED ASSEMBLIES AT ELEVATOR: 2ND FLOOR: 1ST & 2ND LAYERS PRE-ROCK; 3RD FLOOR: 1ST & 2ND LAYER PRE-ROCK AT JOIST BAYS;
		1ST LAYER WELL FACE FULL HEIGHT + 1ST LAYER AT CEILING; 2ND LAYER WELL FACE FULL HEIGHT + 2ND LAYER AT CEILING; 3RD LAYER AT CEILING + HAT CHANNEL; [4TH LAYER AT CEILING OK TO TAPE, MUD AND FIRE-STOP
Partial Correction		
3	Misc	OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT SHOWERS/TUBS AT: 4TH FLOOR 3RD FLOOR 2ND FLOOR 1ST FLOOR
Partial Correction		
4	Misc	2ND FLOOR ELECTRICAL CLOSET: OK TO COVER FIRST LAYER GWB; [2ND LAYER ADJACENT TO ELEVATOR; BASEMENT IT ROOM: ONE LAYER GWB; [2ND LAYER GWB 3RD FLOOR RC CHANNEL UNITS AND CORRIDOR.

All Rough Inspection - Commercial

Mark Harding

Partial

Thursday, September 28, 2017

Partial Correction		
1	Misc	OK TO COVER WHEN READY CEILING & WALL FRAMING & ENCLOSED SYSTEMS AT: 4TH FLR ALL UNITS/SPACES INCLUDING STAIRWELLS 3RD FLR ALL UNITS/SPACES INCLUDING STAIRWELLS 2ND FLR ALL UNITS/SPACES INCLUDING STAIRWELLS 1ST FLR ALL UNITS/SPACES INCLUDING STAIRWELLS BASEMENT CORRIDOR GARAGES
Partial Correction		
2	Misc	RC CHANNEL IN PLACE AT CEILING & WALLS AT: [4TH FLOOR [3RD FLOOR

Partial Correction
3 Misc

SHEAR WALL OK TO COVER WHEN READY AT:
BASEMENT SOUTH STAIRWELL

Comments: