

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161058, Building Permit - Commercial

Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	Mike Copeland	Failed	Friday, September 29, 2017

Corrective Action Required

1	Misc	-MAIN BONDING JUMPER NEEDS TO BE SIZED NO SMALLER THAN THE LARGEST UNGROUNDED CONDUCTOR -SERVICE EQUIPMENT REQUIRED TO HAVE BONDING BUSHINGS BETWEEN SERVICE EQUIPMENT
---	------	---

Comments: