

Inspection Summary

Permit #: PRCOM20161178, Building Permit - Commercial

Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Not Ready	Friday, September 29, 2017

Partial Correction

1 Misc

NOT READY FOR INSPECTION. TOO MANY INCOMPLETE ITEMS. MENTIONED TO THE CONTRACTOR, THE SIDES NEXT TO URINALS NEED TO BE A NON-ABSORBANT SURFACE. TIGHTEN RECEPTACLES, UNCOVER SPRINKLER HEADS, COMPLETE BONDING OF ALL METAL PARTS AND PUMPS AT POOL, EXIT SIGNS NEED TO BE FUNCTIONAL.

Comments: