

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161771, Building Permit - Commercial
Address: 819 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mark Harding	Partial	Friday, September 29, 2017

Partial Correction
1 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT STAIRWELLS:
SOUTH STAIRWELL:
BASEMENT: 1ST LAYER INCLUDING PRE-ROCK; 2ND LAYER PRE-ROCK ONLY;
1ST FLOOR: 1ST LAYER INCLUDING PRE-ROCK; [2ND LAYER INCLUDING PRE-ROCK;
2ND FLOOR: 1ST LAYER INCLUDING PRE-ROCK; [2ND LAYER PRE-ROCK ONLY;
3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK

NORTH STAIRWELL:
1ST FLOOR: [2ND LAYER INCLUDING PRE-ROCK;
2ND FLOOR: [2ND LAYER PRE-ROCK ONLY;
3RD FLOOR: 1ST LAYER INCLUDING PRE-ROCK

Partial Correction
2 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB PRE-ROCK AT ELEVATOR:
BASEMENT: 1ST LAYER; 2ND LAYER
1ST FLOOR: 1ST LAYER; [2ND LAYER;
2ND FLOOR: 1ST LAYER; [2ND LAYER;

Comments: