

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20170916, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Mike Copeland	Partial	Friday, September 29, 2017

Partial Correction

1 Misc

LINE 6 (2 HOUR WALL) WITNESSED ASSEMBLY OF FIRE
INSULATION AND SPRAY BETWEEN AIR GAP IN 2 HOUR WALL.
-ROOF TOP FIRESTOPPING P LINE, 13 LINE

Comments: