



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20172954	Date:	October 02, 2017
Project Title:	GMET COMMUNICATIONS	Applicant:	
Location:	3528 SW MARKET ST, LEES SUMMIT, MO 64082	ABSOLUTE FIRE INC 13906 CENTURY LN GRANDVIEW, MO 64030	
Type of Work:			
Occupancy Group:	UC		
Description:	WHITE BOX FOR FUTURE RETAIL TENANT	Primary: (816) 737-9991	

**drawing is in plan review file

Construction Type: Type VB (Unprotected)

Map Page: 215B

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(verified at inspection)

The existing fire sprinkler system riser shall be current wih all required service and maintenance. A current service tag shall be posted on the systems riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.