

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20172113, Public Works Infrastructure Permit - Commercial

B&B Theatre

Address: 3201 SW FASCINATION DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DE-Fire Line Construction Inspection	Steve Robbins	Partial	Monday, October 02, 2017

Informational

- 1 The water dept. has done the tap off the fireline , the meter and pit has been installed. They put 2 " copper from the fire line to the meter. They will be installing copper from the meter 10FT .Steve Robbins 10/02/2017 12:52 PM

DEI-Storm - Sewer Construction Inspection	Steve Robbins	Partial	Monday, October 02, 2017
---	---------------	---------	--------------------------

Informational

- 1 The contractors connected to the existing storm box. They are pouring the collars this afternoon and trying to backfill before the rain tomorrow.

Informational

- 2 Last week they tied into existing 3-1 and installed 3-2 storm inlet. Over the weekend they install about 70 ft. of storm pipe heading toward storm inlet 3-3. They will be working on this pipe today.Steve Robbins 10/02/2017 9:09 AM

Comments: