

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRRES20170197, Building Permit - Residential

Address: 2223 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822225 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822227 SW BURNINGWOOD LN, LEES SUMMIT, MO 640822221 SW BURNINGWOOD LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	John DiMauro	Passed	Monday, October 02, 2017

Informational

1 John DiMauro 07/27/2017 2:26 PM
Driveway approach cross slope is less than 2.0%

Comments: