



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

| | | | |
|------------------|--|------------|--|
| Permit No: | PRCOM20172339 | Date: | October 02, 2017 |
| Project Title: | PLANET FITNESS | Applicant: | |
| Location: | 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063 | | GOAL FIRE PROTECTION, LLC 13100 SWARTZ RD BONNER SPRINGS, KS 66012 |
| Type of Work: | | | |
| Occupancy Group: | | | |
| Description: | TENANT FINISH FOR NEW GYM | Primary: | (913) 441-3390 |

****invite planner to final to verify rtu screening**

Construction Type: Type IIB (Unprotected)

Map Page: 195K

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(veriifed at inspection)

The existing fire sprinkler system riser shall be current with all required service and maintenance. A current service tag shall be posted on the systems riser.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.