

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit: PRPWFC20171319, Public Works Infrastructure Permit - Commercial
LBP V-A, 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|-------------------|-----------------|---------------------------|
| DEI-Water Line Construction Inspection | Bart Reese | Partial | Tuesday, October 03, 2017 |

Jones Industrial Rd. has been saw cut. Jones Indus. was saw cut for the fire line and domestic service line. City has not approved a street cut. Notified Chad Holthouse that the water lines (fire and domestic service) must be bored under the road.
