

Temporary Certificate of Occupancy

Permit #: PRRES20170078
Address: 1321 NE BRANDYWINE RD, LEES SUMMIT, MO 64064
Inspected On: Tuesday, October 03, 2017
Inspected By: Khanh Nguyen
Expiration Date: 11/3/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Temporary C of O	Tuesday, October 03, 2017

Corrective Action Required:

1	Misc	-RAISE GAS METER -SEAL EXTERIOR -LOCATE AND MAKE ACCESSIBLE THE SEWER TRACER BOX
---	------	--