

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171531, Building Permit - Commercial

Address: 3500 SW MARKET ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mike Copeland	Failed	Tuesday, October 03, 2017

### Corrective Action Required

1	Misc	MC CABLES > 6' ARE REQUIRED TO BE SECURED WITHIN 12" OF JUNCTION BOXES. CHECK ALL
---	------	--

### Comments: