

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172778, Building Permit - Commercial

Address: 2151 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Electrical Inspection - Commercial	Khanh Nguyen	Failed	Tuesday, October 03, 2017

Corrective Action Required

1	Misc	-APPROVAL REQUIRED FROM: DEV. ENGINEERING, PLANNING -COMPLETE ELECTRICAL FOR LIGHT POLES -POWER PANEL: SHALL GROUND PANEL PER CODE; INSTALL BUSHING AT PANEL ENTRANCE FOR CONDUCTORS > #4; COMPLETE THE REST OF THE ELECTRICAL INSTALLATION
---	------	---

Comments: