

Temporary Certificate of Occupancy

Permit #: PRCOM20161178
Address: 1800 NW OBRIEN RD, LEES SUMMIT, MO 64081
Inspected On: Tuesday, October 03, 2017
Inspected By: Mike Copeland Michael Weissenbach
Expiration Date: 11/3/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Mike Copeland	Temporary C of O	Tuesday, October 03, 2017

Partial Correction:

1	Misc	-SUBMIT DOMESTIC BACKFLOW TESTS TO WATER UTILITIES -EXTERIOR SITE WORK INCOMPLETE, FURTHER INSPECTION ITEMS ASSOCIATED WITH SITE WILL BE COMPLETED AS WORK IS COMPLETED -HEALTH DEPARTMENT CONDUCTED PRELIM INSPECTION AND IS OKAY WITH TEMPORARY OCCUPANCY, WILL CONDUCT ANOTHER INSPECTION WHEN KITCHEN IS COMPLETE. -POOL BONDING FOR LADDER NEEDS TO BE INSPECTED -ADJUST CLOSER SPEED FOR ACTIVITY ROOM -INSPECTED RECEPTACLES, BATHROOMS, DOOR HARDWARE, MEANS OF EGRESS -OBTAIN FIRE DEPARTMENT APPROVAL (OKAY FOR TEMP OCCUPANCY)
---	------	---

OTHER INSPECTION ITEMS MAY BE NOTED AT FUTURE
INSPECTIONS

Occupancy Inspection - Fire Michael
Weissenbach

Temporary C of O

Tuesday, October
03, 2017