

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20171395, Building Permit - Commercial

Address: 110 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|-------------|----------|---------------------------|
| Underslab Plumbing Inspection - Commercial | Dale Carter | Failed | Tuesday, October 03, 2017 |

Corrective Action Required

| | | |
|---|------|-----------------------------------|
| 1 | Misc | Install cleanout. OK to backfill. |
|---|------|-----------------------------------|

Comments: