

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20161479, Building Permit - Residential

Address: 3118 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Dale Carter	Failed	Tuesday, October 03, 2017

Corrective Action Required

- | | | |
|---|------|---|
| 1 | Misc | 3. Secure electric receptacle yokes - throughout. |
|---|------|---|

Comments: