

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170595, Building Permit - Residential

Address: 1341 NE BRANDYWINE RD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
DEI-Sidewalk Inspection	Bart Reese	Failed	Tuesday, October 03, 2017

Corrective Action Required

Forms have grade breaks (sidewalk forms).

Comments: Forms must be reset, called contractor, Jose and explained that grade breaks in the walk are unacceptable.