

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171543, Building Permit - Commercial

Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Khanh Nguyen	Failed	Tuesday, October 03, 2017

### Corrective Action Required

1 Misc

FLOOR FRAMING ABOVE BASEMENT ONLY-OK

FLOOR ON THE NORTH SIDE OF THE BASEMENT-TOE NAIL THE JOISTS TO SILL PLATES; HAVE THE STRUCTURAL PLAN AVAILABLE ON SITE. CHECK THE TIE-DOWN STRAPS INSTALLATION

### Comments: