## **Development Services Department**

220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

## **Inspection Summary**

Permit #:PRCOM20171410, Building Permit - Commercial Address: 1621 NW BLUE PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underslab Electrical Khanh Nguyen Partial Wednesday, October 04, 2017

Inspection - Commercial

Corrective Action Required

1 Misc ALL THE UNDERSLAB CIRCUITS TO THE PATIENT CARE ROOMS

MUST BE METAL RACEWAYS (NEC517.13. ALSO CANNOT INSTALL GREEN MC IN UNDERSLAB RACEWAYS EITHER). FLOOR IS OK TO

POUR, BUT THE COMPLIANT CIRCUITS WILL HAVE TO BE

INSTALLED ABOVE FLOOR.

**Comments:**