

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Partial	Wednesday, October 04, 2017

Corrective Action Required

1	Misc	PRELIMINARY FRAMING INSPECTION: 4TH FLOOR: ISSUES IDENTIFIED 3RD FLOOR: ISSUES IDENTIFIED 2ND FLOOR :ISSUES IDENTIFIED 1ST FLOOR:ISSUES IDENTIFIED GARAGE LEVEL:ISSUES IDENTIFIED
Partial Correction 2	Misc	ROOF SHEATHING OK TO COVER WHEN READY AFTER BUTT JOINT GAPS AT SOUTH END ARE ELIMINATED BY REPLACEMENT OF ONE OR MORE 16" SECTIONS OF GAPPED SHEETS.
Partial Correction 3	Misc	Exterior sheathing nailing inspected. Garage portal straps and nailing inspected. OK to cover.

Comments: