

## **CODES ADMINISTRATION**

## Temporary Certificate of Occupancy

Permit #: PRRES20170989

Address: 1691 NE PARKWOOD DR, LEES SUMMIT, MO 64064

Inspected On: Thursday, October 05, 2017

**Inspected By:** Khanh Nguyen

Expiration Date: 11/6/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.** 

Occupancy Inspection - Khanh Nguyen Temporary C of O Thursday, October

Codes Residential 05, 2017

Corrective Action Required:

1 Misc -DECK: LAG DECK LEDGE BOARD TO HOUSE RIM BAND