



LEE'S SUMMIT
MISSOURI



FIRE DEPARTMENT

PLANS REVIEW CONDITIONS

Permit No:	PRCOM20171258	Date:	October 05, 2017
Project Title:	B&J PEERLESS ADDITION	Applicant:	
Location:	2301 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064	ADVANTAGE FIRE PROTECTION SYSTEMS INC 404 B NW 11TH ST BLUE SPRINGS, MO 64015	
Type of Work:			
Occupancy Group:			
Description:	BUILDING ADDITION INTENDED FOR STORAGE	Primary: (816) 224-3400	
Construction Type:	Type IIB (Unprotected)		
Map Page:	175V		

Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.

Sprinkler Plan Review

Reviewed By: Joe Dir

Released for Construction

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:

Field test and acceptance testing of the system will be required prior to the final occupancy inspection. Contact the fire department to schedule testing.(816)969-1300.

The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.