

Temporary Certificate of Occupancy

Permit #: PRCOM20171833
Address: 622 SW 3RD ST, Unit:M, LEES SUMMIT, MO 64063
Inspected On: Friday, October 06, 2017
Inspected By: Khanh Nguyen Michael Weissenbach
Expiration Date: 11/6/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Friday, October 06, 2017

Corrective Action Required:

1	Misc	-FIRE DEPT APPROVA REQUIRED -POST NO SMOKING SIGNAGE AT FRONT ENTRY DOOR -COMPLETE DRYWALL FOR CONSULT RM -RECEPTACLE WITHIN SIX FT OF SINK IN BREAK RM MUST BE GFCI-PROTECTED -POST RESTROOM SIGNAGE
---	------	--

NOTE: RESTROOM IS EXISTING AND NOT IN COMPLIANCE WITH
ACCESSIBILITY REQUIREMENT

Occupancy Inspection - Fire	Michael Weissenbach	Temporary C of O	Friday, October 06, 2017
--	------------------------	------------------	-----------------------------

