

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171570, Public Works Infrastructure Permit - Commercial
Control Services Company
Address: 3621 NE AKIN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Failed	Friday, October 06, 2017

Corrective Action Required

1 Matt Munger 10/06/2017 11:44 AM
Your project is in violation of the Erosion and Sediment control policy.

Silt fence is not intact according to the plans around the site. There is no protection around the storm inlets. ESC devices need to be maintained throughout the duration of the project.

Comments: