

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161761, Building Permit - Commercial
Address: 805 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Framing Inspection - Commercial	Mark Harding	Partial	Friday, October 06, 2017
Partial Correction 1 Misc		SHEAR WALLS AT STAIRWELLS: SOUTH STAIR: 1ST FLOOR; NORTH STAIR: 1ST FLOOR;	
Partial Correction 2 Misc		OK TO COVER WHEN READY INTERIOR VERTICAL STRAPS AT GARAGE PORTALS	
Corrective Action Required 3 FOURTH FLOOR		4TH FLOOR ROUGH FRAMING - CORRECTION ITEMS IDENTIFIED.	
Sprinkler - Hydrostatic Test	Michael Weissenbach	Passed	Friday, October 06, 2017

Comments: