

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20162403, Building Permit - Commercial

Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Commercial</b>	John Borns	Passed	Monday, October 09, 2017

**Comments: IF LAYOUT IS CORRECT FOR CONCENTRIC LOADING OK TO POUR WHEN READY FOUR PIERS AT  $\geq 12$ " DAIM x  $\geq 36$ " DEPTH.**