

**CODES ADMINISTRATION**

**PLAN REVIEW CONDITIONS**

October 09, 2017

SFCS ARCHITECTS  
1927 SOUTH TRYON ST, SUITE 207  
CHARLOTTE, NC 28203

Permit No: PRCOM20173278  
Project Title: JOHN KNOX VILLAGE ASTORIA BUILDING RENOVATION  
Project Address: 1706 NW OBRIEN RD, LEES SUMMIT, MO 64081  
Parcel Number: 62120019200000000  
Location: REPLAT JOHN KNOX RETIREMENT VILLAGE 12TH PLAT LOTS F & G---LOT F  
Type of Work: ALTERATION COMMERCIAL  
Occupancy Group: INSTITUTIONAL, SUPERVISED ENVIRONMENT  
Description: ALTER BUILDING FROM SENIOR APARTMENTS TO ASSISTED CARE - INCLUDES NEW STAIRWAYS

***Revisions Required***

***One or more departments have not approved the permit and the following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and provide three (3) copies of any revised sheets and/or additional information. Please contact the appropriate department regarding clarification of comments.***

Development Services Department (816) 969-1200

Fire Department (816) 969-1300

**Licensed Contractors**

**Reviewed By: Joe Frogge**

**Rejected**

1. Lee's Summit Code of Ordinance, Section 7-130.4 - Business License. (excerpt)

No person, other than a licensed contractor or employees of a licensed contractor, shall engage in electrical, plumbing or mechanical business, construction, installation or maintenance unless duly licensed in accordance with this section.

Action required: MEP subcontractors are required to be listed on permit. Provide company names of licensed MEP contractors.

**Building Plan Review**

**Reviewed By: Joe Frogge**

**Rejected**

1. Missouri Board for Architects, Professional Engineers, Professional Land Surveyors and Professional Landscape Architects – Board Rules, Division 2030 – Chapter 3, 20 CSR 2030-3.060 Licensees Seal Documents must bear design professionals original seal with signature and date. (relevant portion paraphrased – reference original document for additional information)

Action required: Provide at least one copy of plan set with original seals/signatures or provide letters from design professionals attesting to the fact that these copies represent their digital seal.

3. ICC A117.1-2009 Section 404.2.3.2 Swinging Doors. Swinging doors shall have maneuvering clearances complying with Table 404.2.3.2.

---

**CODES ADMINISTRATION**

Action required: Provide at least 18" clearance at latch side of 2nd floor door into stair #1.

4. 2012 IBC 703.2 Fire-resistance ratings. The fire-resistance rating of building elements, components or assemblies shall be determined in accordance with the test procedures set forth in ASTM E 119 or UL 263 or in accordance with Section 703.3. Where materials, systems or devices that have not been tested as part of a fire-resistance-rated assembly are incorporated into the building element, component or assembly, sufficient data shall be made available to the building official to show that the required fire-resistance rating is not reduced. Materials and methods of construction used to protect joints and penetrations in fire resistance-rated building elements, components or assemblies shall not reduce the required fire-resistance rating.

Action required: Add fire ratings to door schedule and provide verification that existing doors and frames have appropriate ratings.

5. ICC A117.1-2009 Section 1004.11.1 Grab Bar and Shower Seat Reinforcement. Reinforcement shall be provided for the future installation of grab bars and shower seats at water closets, bathtubs, and shower compartments. Where walls are located to permit the installation of grab bars and seats complying with Section 604.5 at water closets; grab bars complying with Section 607.4 at bathtubs; and for grab bars and shower seats complying with Sections, 608.3, 608.2.1.3, 608.2.2.3 and 608.2.3.2 at shower compartments; reinforcement shall be provided for the future installation of grab bars and seats complying with those requirements. (see code for exceptions)

Action required: Provide reinforcement for future grab bar installation at all required locations.

6. 2012 IBC 1809.5 Frost protection. Except where otherwise protected from frost, foundations and other permanent supports of buildings and structures shall be protected from frost by one or more of the following methods:

1. Extending below the frost line of the locality;
2. Constructing in accordance with ASCE 32; or
3. Erecting on solid rock.

(see code section for exceptions)

Shallow foundations shall not bear on frozen soil unless such frozen condition is of a permanent character.

Action required: Modify footing details to show that all will be installed below minimum frost depth of 36".

**Fire Plan Review****Reviewed By: Joe Dir****Approved with Conditions**

1. 2012 IFC 907.1.1- Construction documents. Construction documents for fire alarm systems shall be submitted for review and approval prior to system installation. Construction documents shall include, but not be limited to, all of the following: 1. A floor plan which indicates the use of all rooms. 2. Locations of alarm-initiating and notification appliances. 3. Alarm control and trouble signaling equipment. 4. Annunciation. 5. Power connection. 6. Battery calculations. 7. Conductor type and sizes. 8. Voltage drop calculations. 9. Manufacturers, model numbers and listing information for equipment, devices and materials. 10. Details of ceiling height and construction. 11. The interface of fire safety control functions.

ACTION REQUIRED:(information purposes)

Have the fire alarm system contractor provide shop drawings for approval of any modifications to be done to the fire alarm system.

2. 2012 IFC 901.2- Construction documents. The fire code official shall have the authority to require construction documents and calculations for all fire protection systems and to require permits be issued for the installation, rehabilitation or modification of any fire protection system. Construction documents for fire protection systems shall be submitted for review and approval prior to system installation.

ACTION REQUIRED:(information purposes)

---

**CODES ADMINISTRATION**

Have the fire sprinkler system contractor provide shop drawings for approval of any modifications to be done to the fire sprinkler system.

3. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test.

ACTION REQUIRED:(information purposes)

If any fire alarm system devices are added, moved, relocated or replaced in the residences or corridors during the renovation process an acceptance test will be required prior to the final occupancy inspection. Contact the fire department to schedule testing (816)969-1300.

4. 2012 IFC 901.6- Inspection, testing and maintenance. Fire detection, alarm and extinguishing systems shall be maintained in an operative condition at all times, and shall be replaced or repaired where defective. Not required fire protection systems and equipment shall be inspected, tested and maintained or removed.

ACTION REQUIRED:(verified at inspection)

The existing fire sprinkler system shall be current with all required service and maintenance. A current service tag shall be posted on the systems riser.

5. Restrooms

ACTION REQUIRED:(information purposes)

If fire sprinklers are not already existing in the bathrooms to be renovated, the new square footage puts them at 55 square feet which NFPA 13R requires them to have sprinklers installed.

6. Emergency lighting

ACTION REQUIRED:(information purposes)

Maintain all emergency lighting throughout the corridors and stairways during all construction phases.

7. Fire extinguishers

ACTION REQUIRED:(information purposes)

Maintain fire extinguishers in the corridors. If moved during construction they shall be replaced prior to their final occupancy inspection.

***The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.***