

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20162083, Public Works Infrastructure Permit - Commercial  
WATER UTILITIES FACILITY  
Address: 1200 SE HAMBLER RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Brice Lawson	Failed	Tuesday, October 10, 2017

Corrective Action Required

- 1 There are problems with the erosion control devices on your site.  
Brice Lawson 10/10/2017 10:25 AM

The silt fence that is in front of FI 50C has a hole in it. Replace this section of silt fence.

The silt fence that is located south of the south driveway approach is damaged. Make necessary repairs to this section of silt fence.

Some of the gutter buddies that have been placed at the storm structures are damaged/torn. Replace the damaged gutter buddies.

The temporary sediment trap located in the northwest corner of the site filling up with silt. The rock berm for this trap has partially washed and moved. Remove silt from the temporary sediment trap and rebuild rock berm.

Comments: