

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20172692, Building Permit - Commercial

Address: 1215 NE RICE RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Failed	Tuesday, October 10, 2017

### Corrective Action Required

1	Misc	-PATCH HOLES IN TENANT SEPARATION WALL -SUPPORT ELECTRICAL BOX
---	------	---

### Comments: