

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOMCOM20161756, Building Permit - Commercial

Address: 795 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Passed	Tuesday, October 10, 2017

Comments: RELEASE ELECTRICAL SERVICE AT NORTH END OF BUILDING. SOUTH END METERS WERE RELEASED EARLIER.