

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20170985, Building Permit - Commercial

Address: 1706 NW CHIPMAN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Commercial</b>	John Borns	Passed	Wednesday, October 11, 2017

**Comments: 2/0 SERVICE CONDUCTORS REPLACED WITH 3/0. RELEASE ELECTRICAL SERVICE FOR RE-ACTIVATION.**