

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial  
LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

| <b>Inspection:</b> | <b>Inspector:</b> | <b>Outcome:</b> | <b>Date:</b>                      |
|--------------------|-------------------|-----------------|-----------------------------------|
| DEI-Site Visit     | Matt Munger       | Partial         | Wednesday,<br>October 11,<br>2017 |

Informational

- 1 No workers were present, I observed locates in place along both sides of the NE Jones Industrial Rd.

Silt fences are still down and Storm Inlet devices will need to be put in place. I contacted Kevin on 10/10/17 in regards to Erosion Control issues and he stated they will get to it this week.

Matt Munger 10/11/2017 9:45 AM

**Comments:**