

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRCOM20171543, Building Permit - Commercial

Address: 221 NW CHIPMAN RD, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Rough Framing Inspection - Commercial</b>	John Borns	Partial	Wednesday, October 11, 2017

Partial Correction

1 Misc

OBSERVATION OF EXTERIOR WALL SHEATHING: FASTENER  
PATTERN COMPLIES WITH DRAWING NOTE. HOWEVER ALL NAILS  
ARE OVERDRIVEN 1/8" TO 1/4".

**Comments:**