

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial

Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	John Borns	Partial	Wednesday, October 11, 2017

Partial Correction

1	Misc	OK TO COVER WHEN READY SHEAR WALL SHEATHING AT STAIRWELLS 1ST LEVEL
---	------	---

Partial Correction

2	Misc	OK TO COVER WHEN READY FRAMING & ENCLOSED SYSTEMS AT PRE-ROCK WALL SECTIONS FOR TUBS & SHOWERS AT: 4TH FLOOR; 3RD FLOOR; 2ND FLOOR; 1ST FLOOR;
---	------	---

Comments: