

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20171896, Building Permit - Residential

Address: 1820 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|   |             |          |                          |
|---|-------------|----------|--------------------------|
| Inspection:                               | Inspector:  | Outcome: | Date:                    |
| <b>All Rough Inspection - Residential</b> | Dale Carter | Failed   | Friday, October 13, 2017 |

### Corrective Action Required

|   |      |   |
|---|------|---|
| 1 | Misc | 6. BSMT: Firestop over deadspace behind shower. *solid blocking |
|   |      | 14. 2nd FLR: Nail siding. *east and west walls                  |
|   |      | 17. 2nd FLR: Fully install/nail snow blocking. *master closet   |

### Comments: