

PUBLIC WORKS ENGINEERING DIVISION

Field Engineering Inspections Site Visit

Permit #: PRPWFC20162840, Public Works Infrastructure Permit - Commercial
Law office of Cameron Hoorfar
Address: 415 SW JEFFERSON ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Nick Lightner	Failed	Monday, October 16, 2017

Corrective Action Required

- 1 Your project is in violation of the Erosion and Sediment control policy.

Call Ahmad to let him know that silt is leaving the site and is on the sidewalk, which needs to be cleaned up and the sediment fence needs to be fixedd.Nick Lightner 10/16/2017 8:39 AM

Comments: