

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20172339, Building Permit - Commercial

Address: 300 SW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Monday, October 16, 2017

Partial Correction

1 Misc

EAST 1 HOUR WALL DIVIDING THIS SPACE FROM ADJOINING SPACE: PLAN CALLS FOR 5/8THS X GYP ON EACH SIDE. WEST SIDE OF WALL LAYER IS APPROVED. **EAST FACE OF WALL OK TO TAPE, MUD AND FIRE-STOP WHEN READY.**

Comments: