

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial
Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|----------------------------------|--------------|----------|--------------------------|
| Rated Assembly Inspection | Mark Harding | Partial | Monday, October 16, 2017 |

Partial Correction
1 Misc

OK TO COVER RATED ASSEMBLIES AT STAIRWELLS:

SOUTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; [2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS;

NORTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; [2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; [2ND LAYER 5/8" TYPE X GWB PRE-ROCK AT TRUSS-JOIST BAYS;

4TH FLOOR -STAIRS 1ST LAYER

Partial Correction

2 Misc

OK TO COVER RATED ASSEMBLIES PRE-ROCK AT ELEVATOR
SHAFT:
FIRST FLOOR: 1ST & 2ND LAYERS PRE-ROCK AT TRUSS-JOIST
BAYS;

SECOND FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS; 2ND
LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

Partial Correction

3 Misc

OK TO TAPE, MUD, AND FIRESTOP 5/8" TYPE X PRE-ROCK GWB
AT TUB/SHOWER WALLS AT:

4TH FLOOR

3RD FLOOR

2ND FLOOR

1ST FLOOR

2ND-LAYERS

2ND -4TH FLOOR

Partial Correction

4 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT CEILINGS AND
WALLS AT: 1ST FLOOR IT ROOM 1ST LAYER:

Comments: