

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171816, Building Permit - Residential

Address: 405 SE WEISS CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Mike Copeland	Passed	Monday, October 16, 2017

All Rough Inspection - Residential	Mike Copeland	Failed	Monday, October 16, 2017
---	---------------	--------	--------------------------

Corrective Action Required

1	Misc	<ol style="list-style-type: none">1. Truss hanger over 1st floor ne bedroom.2. Master bedroom rear wall, not framed per detail S 4.1.3. Flash plumbing vent master bath.4. Security block walkout door.5. Missing Double floor joist basement above far north post. See floor joist layout.6. Firestop above foyer closet and around fireblocking for garage fur out. <p>Okay to insulate.</p>
---	------	---

Electrical Service Inspection - Residential	Mike Copeland	Passed	Monday, October 16, 2017
--	---------------	--------	--------------------------

Gas Service Inspection - Residential	Mike Copeland	Passed	Monday, October 16, 2017
---	---------------	--------	--------------------------

Erosion Control

Mike Copeland Partial

Monday, October 16, 2017

Partial Correction

1 Misc

Maintain rear property erosion control

Comments: