

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20170717, Building Permit - Residential

Address: 3344 SW JESSIE LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Dale Carter	Failed	Monday, October 16, 2017

### Corrective Action Required

- |   |      |  |
|---|------|--|
| 1 | Misc | 1. BSMT: Double-joists under kitchen island. *Re-install duct support.<br>3. BSMT: Anchor sill plates within 12" of ends of plates - *Northwest corner.<br>5. BSMT: Secure SEC above panel.<br>6. BSMT: Joist overnotched over the future bath.<br>7. BSMT: Stub vent for future bath.<br>10. ATTIC: Slope and support DWV.<br>11. ATTIC: Protect NM within 6' of access.<br>12. ROOF: Support legs should be spaced no more than 4'.<br>*Please have approved plans onsite. |
|---|------|--|

Comments: