

# Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

## Inspection Summary

---

Permit #:PRRES20171228, Building Permit - Residential

Address: 617 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081619 NW LILAC PL, LEES SUMMIT, MO 64081615 NW LILAC PL, Unit:B, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Dale Carter	Failed	Monday, October 16, 2017

### Corrective Action Required

1	Misc	UNIT 615 ONLY: 2. Install basement window.  OK to insulate / rock.
---	------	---

<b>All Rough Inspection - Residential</b>	Dale Carter	Failed	Monday, October 16, 2017
---	-------------	--------	--------------------------

### Corrective Action Required

1	Misc	1. Nailing pattern on party wall and patch hole. 2. Install basement window. 3. Support DWV in basement at least every 4'. 4. Bond gas pipe.
---	------	---

<b>Rated Assembly Inspection</b>	Dale Carter	Partial	Monday, October 16, 2017
----------------------------------	-------------	---------	--------------------------

### Corrective Action Required

1	Misc	UNIT 615 ONLY - Inspected & Passed
---	------	------------------------------------

**Comments:**