

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial
LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Erosion Sediment Control (ESC) Inspection	Matt Munger	Partial	Monday, October 16, 2017

Informational

- 1 The storm inlets have material in place to prevent silt from getting into the storm sewer. West side of the site needs a silt fence in place. Matt Munger 10/16/2017 2:20 PM

DEI-Site Visit	Matt Munger	Partial	Monday, October 16, 2017
----------------	-------------	---------	--------------------------------

Informational

- 1 No workers were present. The water pipe that was on site was ANSI/AWWA C900 6" and a PC 235. Matt Munger 10/16/2017 9:17 AM

Comments: