

Temporary Certificate of Occupancy

Permit #: PRCOM20172692
Address: 1215 NE RICE RD, LEES SUMMIT, MO 64086
Inspected On: Tuesday, October 17, 2017
Inspected By: Khanh Nguyen
Expiration Date: 11/17/2017 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

| Inspection: | Inspector: | Outcome: | Date: |
|--|--------------|------------------|------------------------------|
| Occupancy Inspection - Codes Commercial | Khanh Nguyen | Temporary C of O | Tuesday, October 17, 2017 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -OBTAIN FIRE DEPT APPROVAL -INSTALL GFCI RECEPTACLE WITHIN SIX FT OF THE SINK -INSTALL DAMPER FOR DRYER EXHAUST TERMINAL |
|---|------|--|