

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161758, Building Permit - Commercial

Address: 789 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Failed	Wednesday, October 18, 2017

Corrective Action Required

1 Misc

Corrective Action Required

2 Misc

P/L LIGHTS TO BE INSTALLED

Corrective Action Required

3 Misc

BOLLARD LIGHTS TO BE INSTALLED

Corrective Action Required

4 Misc

POOL EQUIPMENT ROOM TO BE INSPECTED

Corrective Action Required

5 Misc

HANDRAILS REQUIRED AT STAIR TO POOL

Corrective Action Required

6 Misc

PANEL SCHEDULES MUST BE SPECIFIC, E.G. "RECEPTACLES" TOO GENERAL

Corrective Action Required

7 Misc

RESOLVE ANY ISSUES WITH
- FIRE DEPT
- WATER DEPT(NO-SHOW)

Occupancy Inspection - Fire	Michael Weissenbach	Not Ready	Wednesday, October 18, 2017
------------------------------------	---------------------	-----------	-----------------------------

Comments: SUCCESSFUL FIRE DEPARTMENT RE-INSPECTION REQUIRED FOR TEMPORARY OCCUPANCY.