
PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20171319, Public Works Infrastructure Permit - Commercial
LBP V-A

Address: 2900 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
DEI-Backflow Preventer and Vault	Matt Munger	Partial	Thursday, October 19, 2017

Informational

- 1 Matt Munger 10/19/2017 9:34 AM Observerd workers installing the BFP in the vault. I reminded the workers as well as Chad H. about using the 3M Rubberized Spray on all bolts.

Comments:
