

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20171501, Building Permit - Residential

Address: 1804 SW BLACKSTONE PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Dale Carter	Failed	Thursday, October 19, 2017

Corrective Action Required

1 Misc

2. BSMT: Install window.
3. BSMT: Anchor column.
4. 1st FLR: Sill-plate anchor in garage.

OK to insulate & rock, provided the above items are left exposed for re-inspection.

Comments: