

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20161765, Building Permit - Commercial
Address: 801 NW DONOVAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Partial	Thursday, October 19, 2017

Partial Correction
1 Misc

OK TO COVER RATED ASSEMBLIES AT STAIRWELLS:

SOUTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; 2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS; **[2ND LAYER AT STAIRWELL FACE;**

4TH FLOOR: 1ST & **[2ND LAYER AT STAIRWELL FACE;**

NORTH STAIRWELL:

FIRST FLOOR 1ST & 2ND LAYERS 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X; [2ND LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER 5/8" TYPE X MOLD-TOUGH GWB INCLUDING PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8"

Partial Correction
2 Misc

TYPE X GWB PRE-ROCK AT TRUSS-JOIST BAYS; **[2ND LAYER AT STAIRWELL FACE;**

4TH FLOOR: STAIRS 1ST LAYER; 1ST & **[2ND LAYER AT STAIRWELL FACE;**

OK TO COVER RATED ASSEMBLIES PRE-ROCK AT ELEVATOR SHAFT:

FIRST FLOOR: 1ST & 2ND LAYERS PRE-ROCK AT TRUSS-JOIST BAYS;

SECOND FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS; 2ND LAYER 5/8" TYPE X PRE-ROCK AT TRUSS-JOIST BAYS;

THIRD FLOOR: 1ST LAYER PRE-ROCK AT TRUSS-JOIST BAYS;

Partial Correction
3 Misc

OK TO TAPE, MUD, AND FIRESTOP 5/8" TYPE X PRE-ROCK GWB AT TUB/SHOWER WALLS AT:

4TH FLOOR

3RD FLOOR

2ND FLOOR

1ST FLOOR

2ND-LAYERS:

2ND - 1ST FLR @ UNITSIDE CORR&STAIRWELL WALLS

2ND -4TH FLOOR

Partial Correction
4 Misc

OK TO COVER WHEN READY 5/8" TYPE X GWB AT CEILINGS AND WALLS AT: 1ST FLOOR IT ROOM 1ST LAYER:

Comments: