

Development Services Department

220 SE Green Street Lee's Summit, MO 64063

(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20170717, Building Permit - Residential

Address: 3344 SW JESSIE LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Dale Carter	Failed	Thursday, October 19, 2017

Corrective Action Required

- | | | |
|---|------|--|
| 1 | Misc | 3. BSMT: Anchor sill plates within 12" of ends of plates -
*Northwest corner. |
| | | 10. ATTIC: Slope and support DWV. (over laundry) |
| | | 12. ROOF: Support legs should be spaced no more than 4'. |

Comments: